



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx PRE 19.0081X	Page 1 of 4	<u>Certificate history:</u>
Status:	Current	Issue No: 2	Issue 1 (2020-07-29) Issue 0 (2020-03-26)
Date of Issue:	2025-04-07		
Applicant:	Euromisure WIKA Instruments S.a.s. di WIKA Italia S.r.l. Viale De Gasperi, 48 Bareggio (MI) 20008 Italy		
Equipment:	Pressure switches series BA and temperature switches series TA		
Optional accessory:			
Type of Protection:	Ex db, Ex tb		
Marking:	Ex db IIC T6 or T4 Gb Ex tb IIIC T85°C or T135°C Db		

Approved for issue on behalf of the IECEx
Certification Body:

Asle Kaastad

Position:

Certification Manager

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DNV Product Assurance AS
Veritasveien 1
1363 Høvik
Norway





IECEx Certificate of Conformity

Certificate No.: **IECEx PRE 19.0081X**

Page 2 of 4

Date of issue: 2025-04-07

Issue No: 2

Manufacturer: **Euromisure WIKA Instruments S.a.s. di WIKA Italia S.r.l.**
Viale De Gasperi, 48
Bareggio (MI) 20008
Italy

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-1:2014 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

NO/PRE/ExTR19.0078/01

NO/PRE/ExTR19.0078/02

Quality Assessment Report:

NO/DNV/QAR13.0013/08



IECEx Certificate of Conformity

Certificate No.: **IECEx PRE 19.0081X**

Page 3 of 4

Date of issue: 2025-04-07

Issue No: 2

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Series BA** Bourdon pressure switches and series TA*** Bourdon temperature switches are constituted by a flameproof enclosure and by a Bourdon sensing element internally mounted to the enclosure itself. The enclosure is intended to contain one or two microswitches (contacts) and a terminal block used to electrically connect them to an external control circuit. The microswitches are directly operated by the element sensitive to pressure (pressure switches) or by a thermometric system.

The degree of protection is IP66 according to the Standard IEC 60529:2001

SPECIFIC CONDITIONS OF USE: YES as shown below:

The pressure switches series BA** can be mounted only on nonflammable process fluids.

The width of the flameproof joints is greater than the values specified in the tables of 60079-1 standard.



IECEx Certificate of Conformity

Certificate No.: **IECEx PRE 19.0081X**

Page 4 of 4

Date of issue: 2025-04-07

Issue No: 2

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Change of company name.

Annex:

[Annex to IECEx PRE 19.0081X issue 2_1.pdf](#)

ANNEX TO CERTIFICATE: IECEx PRE 19.0081X ISSUE 2

PARAMETERS RELATING TO THE SAFETY

MAXIMUM ELECTRICAL RATING

- 380 V / 20 A c.a. or 250V /20 A c.a.
- 220 V / 0.5 A (30V / 2A) d.c.

Pressure switch: process temperature (media temperature at the process connection)

The limits of process temperature are: $-60 \div +85$ °C

The limits of process temperature are: -60 ... +65 °C				
Temperature Classification	Ambient temperature range (Tamb)	Min process temperature (Media temperature at the process connection of the instrument)	Max process temperature (Media temperature at the process connection of the instrument)	Max Current (resistive load)
T6	-60 .. +60 °C	-60 °C	+60 °C	(depending on the microswitches selected) See Nameplate
T5				
T4				
T3				
T2				
T1				
	-60 .. +85 °C		+85 °C	

Temperature Switch: Process Temperature (Media Temperature At The Bulb)

For the instrument model TA*** (stem for remote mounting or helical bulb for ambient temperature) the following table is applicable

Temperature Classification	Ambient temperature range (Tamb)	Max Current (resistive load)
T6	-60 ..+60 °C	(depending on the microswitches selected) See Nameplate
T5		
T4		
T3	-60 ..+85 °C	
T2		
T1		

MARKING

Marking has to be readable and indelible; it has to include the following indications:

Instruments series BA/TA:

- Euromisure WIKA Instruments S.a.s. di WIKA Italia S.r.l.
- Viale De Gasperi, 48 - 20008 Bareggio (MI) – ITALY
- BA** and TA*** (1)
- IECEx PRE 19.0081 X
- (Serial number)
- IECEx Marking (see below)
- Tamb: (*)
- Tcable: (*)
- Warning: POWER OFF BEFORE OPENING

(1) Type is completed by numbers and /or letters corresponding to manufacturing variations.

The marking and type of protection for the instruments series BA** and TA*** (CCE06) are:

- Ex db IIC T6 Gb (Tamb from -60 to +60°C); Ex tb IIIC T85°C Db IP66 (Tamb from -60 to +60°C)
- Ex db IIC T4 Gb (Tamb from -60 to +85°C); Ex tb IIIC T135°C Db IP66 (Tamb from -60 to +85°C)

(*) See table below

Range of Ambient Temperature	Temperature Class		Cable Temperature
	Gas	Dust	
-60°C ≤ Tamb ≤ +60°C	T6	T85°C	N/A
-60°C ≤ Tamb ≤ +85°C	T4	T135°C	95°C

ROUTINE EXAMINATIONS AND TESTS

In accordance with § 16.2 of the IEC 60079-1 standard, the equipment defined above is exempted of routine test due to the fact that it has undergone a static type test at 4 times the reference pressure under 40 bar for ambient down to -60°C.