

CERTIFICATE OF COMPLIANCE

Certificate Number 2021-04-29-E312413
Report Reference E312413-D1002-4/A0/C0-UL
Date 2021-04-29

Issued to: WIKA ALEXANDER WIEGAND SE & CO. KG
Applicant Company: ALEXANDER-WIEGAND-STRASSE 30
63911 KLINGENBERG GERMANY

Listed Company: SAME AS APPLICANT

**This is to certify that
representative samples of**

PSD-30, PSD-31, PSD-30 IO-Link, PSD-31 IO-Link, PSD-4 are
Electronic Pressure Switches, FSD-3 and FSD-4 are Electronic
Flow switch, TSD-30, TSD-30 IO-Link are Electronic
Temperature Switches

PSD-30, PSD-31, PSD-30 IO-Link, PSD-31 IO-Link, PSD-4,
FSD-3, TSD-30, TSD-30 IO-Link, FSD-4

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 61010-1 - Edition 3 - Revision Date July 19, 2019
CSA C22.2 NO. 61010-1-12 - Edition 3 - Revision Date
November, 2018

Additional Standards: IEC 60529

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information.

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

