



Ontploffingvoorkomingstegnologie  
Explosion Prevention Technologies

# MTEEx Laboratories

**Centurion**  
Unit 1 Wierda Place  
17 Hilda Ave  
Hennospark  
0157

**Cape Town**  
Unit 3 Marcian Park  
Cincaut Cres  
Saxenburg Park  
7580

## INSPECTION AUTHORITY (IA) CERTIFICATE

**WIKA INSTRUMENTS (PTY) LTD.**  
**P.O. BOX 75225**  
**GARDENVIEW**  
**2047**

**Issued:** 2024/03/11  
**Expire:** 2027/03/11  
**Revision:** 0  
**Job File Number:**2529

Applicant:  
**WIKA INSTRUMENTS (PTY) LTD.**

For validity purposes, the following Marking must be added to all equipment covered by this certificate:

**IA Number:** MTEEx-S/24.0114 X  
**Manufacturer:** WIKA Alexander Wiegand SE Co. KG  
**Supplier:** Wika Instruments (Pty) Ltd.  
**Equipment:** Pressure transmitter  
**Model/Type:** PEU-2\*  
**Ex Rating:** Refer to Clause 1.  
**Serial No.:** All units imported between the issue and expiry dates of this certificate.



### Standards used:

<b>SANS 60079-0: 2019 Ed.6</b> <b>IEC 60079-0: 2017 Ed.7</b>	<b>Explosive atmospheres - Part 0: Equipment — General requirements.</b>
<b>SANS 60079-11: 2012 Ed.4</b> <b>IEC 60079-11: 2011 Ed.6</b>	<b>Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i".</b>
<b>SANS 60079-26: 2022 Ed.4</b> <b>IEC 60079-26: 2021 Ed.4</b>	<b>Explosive atmospheres - Part 26: Equipment with Separation Elements or combined Levels of Protection</b>

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

This certification indicates compliance with R10.1 of the Mines Health and Safety Act and/or EMR 9(3) of the Occupational Health and Safety Act, provided that the apparatus is used as prescribed in accordance with the following **Notes**:

- 1) Compliance with any conditions set out in this Certificate.
- 2) This certificate only covers equipment imported between the "Issued" and "Expiry" dates of this certificate.
- 3) When the supporting Q.A.N. (Quality Assurance Notification) of the equipment manufacturer expires, it is the responsibility of the applicant (as mentioned above) to submit a valid Q.A.N to MTEEx Laboratories.
- 4) It is the responsibility of the supplier to ensure that the marking label complies with the requirements of the relevant regulator.
- 5) Once issued, the certificate remains valid for the serviceable lifecycle of the device. The state of the device is validated by visual or close inspections, by the end user, at intervals not exceeding two years.

Reviewed By + Signature (TL):	A. van Niekerk	
Approved By + Signature (CB): (MTEEx Laboratories Technical Signatory)	D. Young	



MTEEx Laboratories is an Accredited Test Laboratory (ATL) in terms of the ARP 0108: "Regulatory Requirements for Explosion-Protected Apparatus".

## 1. OVERVIEW

The pressure transmitter type PEU-2\* converts a pressure into a digital Signal which is transmitted via UART-interface (Universal Asynchronous Receiver Transmitter) to an external device, e.g. to a radio unit. It is intended for measuring the pressure in an area with potentially explosive atmosphere (gas/dust). The PEU-2\* is intended for connection to intrinsically safe circuits of external devices.

### Marking

<b>Model</b>	<b>Ex-marking</b>
PEU-2*_*C*_*****_*****_****	Ex ia IIC T6...T1 Ga
PEU-2*_*D*_*****_*****_****	Ex ia IIC T6...T1 Ga/Gb
PEU-2*_*E*_*****_*****_****	Ex ia IIC T6...T1 Gb
PEU-2*_*H*_*****_*****_****	Ex ia IIIC T135°C Da
PEU-2*_*F*_*****_*****_****	Ex ia IIIC T135°C Da/Db
PEU-2*_*G*_*****_*****_****	Ex ia IIIC T135°C Db

### Subject and Type

Pressure transmitter type PEU-2\*

### Type code.

PEU - 2a - bcd - \* - \*\*\*\*\* - ef\*\*\*\*\* - \*\*\*\*

#### **a pressure connection option**

“0” = pressure channel

“1” = front flush

#### **b approvals**

“A, I, W, E, G, J, K, P, U, 1, 2, 3, 4 or 5” = ATEX + IECEx “C, D, F” = IECEx

#### **c type of ignition protection**

“I” = Ex ia

#### **d zone**

“C” = Zone 0: Ex ia IIC T6...T1 Ga

“D” = Zone 1 adjacent to zone 0: Ex ia IIC T6...T1 Ga/Gb

“E” = Zone 1: Ex ia IIC T6...T1 Gb

“H” = Zone 20: Ex ia IIIC T135°C Da

“F” = Zone 21 adjacent to zone 20: Ex ia IIIC T135°C Da/Db

“G” = Zone 21: Ex ia IIIC T135°C Db

#### **ef process connection (maximum media temperature)**

e = any character

f = “4” or “2” model with cooling element for high media temperature

f = any character other than “4” or “2” for standard model

In the complete type denomination, the characters “\*” can be replaced by further numbers or letters which characterize different variants without influence on explosion protection.

**Listing of all components used**

Subject and type	Certificate	Standards
Pressure transducer TIS-2*	IECEX BVS 14.0051U	IEC/SANS 60079-0:2017, Ed. 7.0 IEC/SANS 60079-11:2011, Ed. 6.0 IEC/SANS 60079 26:2021, Ed. 4

**2. REASON FOR REVIEW**

Revision 0: ARP 0108 requirement (Initial IA Certificate).

**3. DOCUMENTATION PROVIDED**

- EU - Type Examination Certificate (BVS 23 ATEX 046 X, Issue 00).
- IECEX Certificate of Conformity (IECEX BVS 23.0027 X, Issue 0).
- IECEX Quality Assessment Report (DE/BVS/QAR07.0010/19).

**4. ELECTRICAL / SAFETY PARAMETERS****Electrical parameters**

Supply and signal circuit

Connection via M12-plug

Maximum input voltage	$U_i$	DC	6.7	V
Maximum input current	$I_i$		250	mA
Maximum input power	$P_i$		300	mW
Effective internal capacitance	$C_i$		4.4	nF
Effective internal inductance	$L_i$			negligible

The pressure transmitter PEU-2\* has to be considered as power supply circuit with the following values:

Maximum output current <sup>(1)</sup>	$I_o$		400	mA
Maximum output voltage (= $U_i$ ) <sup>(1)</sup>	$U_o$	DC	6.7	V

<sup>(1)</sup> (short time; from capacitor discharge time constant:  $5 \cdot \tau < 25$  ms; based on IECEX BVS 14.0051U).

**Thermal parameters**

Ambient temperature range for ambient temperature = media temperature

Temperature class T1 to T4 -40 °C ... 80 °C

Maximum surface temperature T135°C for Dust ex- atmosphere -40 °C ... 80 °C

Ambient temperature range for high media temperature range

Temp. class	Maximum media temperature [°C]	Maximum media temperature [°C]	
		All models except PEU-2*_*_*_*_*_*_*_*_*2*_*_*_*_*_*_*_*_* and PEU-2*_*_*_*_*_*_*_*_*4*_*_*_*_*_*_*_*_* (Models without cooling element)	Models PEU-2*_*_*_*_*_*_*_*_*2*_*_*_*_*_*_*_*_*, PEU-2*_*_*_*_*_*_*_*_*4*_*_*_*_*_*_*_*_* (Models with cooling element)
T3	150	N/A	40
T4	120	30	50
T4	105	40	50
T4	85	80	80
T5	85	80	80
T6	70	70	70

## 5. INSTALLATION INSTRUCTIONS

The instructions provided with the product shall be followed in detail to assure safe operation.

## 6. CONDITIONS OF CERTIFICATE (X)

- The permissible ambient temperature range depends on the temperature class. Refer to the manufacturer's instructions.
- For functional reasons, the partition wall (membrane) to the wetted area has a wall thickness < 0.2 mm. In the application it has to be,
  - ensured, that an impairment of the separation wall e.g. by aggressive media or mechanical hazards is excluded.
- In gas-explosive areas, the device shall be installed in such a way that electrostatic charging at the type label is excluded.
- In dust-explosive areas with conductive dust IIIC, the intrinsically safe circuit is not safely separated from earth/potentially earthed metal parts. Along the intrinsically safe circuit, potential equalization must exist.

## MTEEx Laboratories

Note: This document may not be reproduced except in full.

MTEEx Laboratories takes no responsibility for any non-conforming tests / assessments / results which is not in compliance with the relative Standards. By marking the equipment as mentioned in the documentation, the manufacturer takes full responsibility that the equipment has indeed complied with the original type assessment and has been subjected to any routine verification(s) / test(s) respectively.

**End of Certificate**