

Manufacturer information (following NAMUR recommendation 53)

1. Type of device

- ☒ Field device / Signal processing device
☐ Monitoring-operating system / Hand held terminal / ...
☐ Modem / Interface

Manufacturer: WIKA Alexander Wiegand SE & Co. KG

Device: Digital temperature transmitter

Model: T15

Previous software version: 1.0.4

2. Firmware or software and hardware

I. New software version: 1.0.5 & 1.0.6

Identification of new firmware version:

- Firmware is written on the label of device, which is also stored in device
- Firmware can be read out of the transmitter using configuration unit PU448 and configuration software WIKAsoft-TT

Changes to previous version:

- Firmware:
Optimization of the short-circuit detection functionality

II. Changes of hardware:

/

3. Compatibility

Is compatibility given after installation of the updated software / firmware?

- ☒ Yes
☐ No (enter reason)

4. Documentation

	Previous	New
Operating instructions	12/2015	06/2016
Data sheet	10/2015	05/2016
Safety manual	/	/
"SIL" certificate	/	/
Further Approvals	Current versions see WIKA homepage	

5. Price

Change in price of device in comparison with previous version?

- ☐ Yes, new list price of device:
☒ No